



DETAIL B
FIRE WALL INSTALLATION

DETAIL - A
COMBI UNIT INSTALLATION

SIDE VIEW

- NOTE:**
1. BOND COMBI TO TRANSFORMER TANK.
 2. USE 16-35mm SQ. COPPER OR EQUIVALENT FOR GROUNDING BY CROWFOOT EARTH.
 3. BOND THE LV NEUTRAL ONTO THE TRANSFORMER TANK ON THE LV SIDE.
 4. BOND THE COMBI EARTH ONTO THE TRANSFORMER TANK ON THE HV SIDE.



DRAWN K.R	20/03/2021	LIVE LINE TECHNOLOGY www.liveline.co.za	
CHECKED K.R			
QA		TITLE	
MFG		BOTSWANA SS 500kVA_33kv_11kv	
APPROVED KEVIN RISI		SIZE D	DWG NO COMBI - 006/21
Tel: +27184685080		SCALE - 1:1	REV
sales@liveline.co.za			SHEET 1 OF 2