



DETAIL - A
COMBI UNIT INSTALLATION

SIDE VIEW

NOTE:
 1. BOND COMBI TO TRANSFORMER TANK.
 2. USE 16-35mm SQ. COPPER OR EQUIVALENT FOR GROUNDING BY CROWFOOT EARTH.



DRAWN K.R	20/03/2021	LIVE LINE TECHNOLOGY www.liveline.co.za	
CHECKED K.R			
QA		TITLE	
MFG		BOTSWANA SS 500kVA_33kv_11kv	
APPROVED KEVIN RISI		SIZE D	DWG NO COMBI - 006/21
Tel: +27184685080		SCALE - 1:1	REV
sales@liveline.co.za			SHEET 1 OF 2