



**NOTE:**  
 1. BOND COMBI TO TRANSFORMER TANK.  
 2. USE 16-35mm SQ. COPPER OR EQUIVALENT FOR GROUNDING BY CROWFOOT EARTH.



DRAWN	K.R	29/03/2021
CHECKED	K.R	
QA	QA	
MFG		
APPROVED	KEVIN RISI	
	Tel: +27184685080	
	sales@liveline.co.za	

<b>LIVE LINE TECHNOLOGY</b> www.liveline.co.za		
TITLE <b>MASSINGIR PT 500KVA GROUND MOUNTED TRANSFORMER COMBI UNIT INSTALLATION</b>		
SIZE	DWG NO	REV
D	COMBI-007/21	
SCALE - 1:1		SHEET 1 OF 1