



FRONT VIEW

SIDE VIEW

BACK VIEW

DETAIL - A
COMBI UNIT INSTALLATION

- NOTE:
1. BOND COMBI TO TRANSFORMER TANK.
 2. USE 16-35mm SQ. COPPER OR EQUIVALENT FOR GROUNDING BY CROWFOOT EARTH.
 3. ENSURE THAT JUMPERS DO NOT INTERFERE WITH FUSEOPERATION.
 4. REMOVE OLD SURGE ARRESTERS.



DRAWN K.R	01/04/2021	LIVE LINE TECHNOLOGY www.liveline.co.za	
CHECKED K.R		TITLE MV THREE PHASE H-POLE TRANSFORMER STRUCTURE UGANDA & KENYA.	
QA		SIZE D	DWG NO COMBI - 008/21
MFG		SCALE - 1:1	REV
APPROVED KEVIN RISI		SHEET 1 OF 1	
Tel: +27184685080			
sales@liveline.co.za			