



FRONT VIEW

SIDE VIEW

BACK VIEW

DETAIL - A
LV NEUTRAL EARTHING
(CU BONDING CABLE 16-35mm SQ.)

DETAIL-B
TRANSFORMER TANK EARTH POINT
(CU BONDING CABLE 16-35mm SQ.)

DETAIL - C
COMBI UNIT INSTALLATION

- NOTE:
1. BOND COMBI TO TRANSFORMER TANK.
 2. USE 16-35mm SQ. COPPER OR EQUIVALENT FOR GROUNDING BY CROWFOOT EARTH.
 3. ENSURE THAT JUMPERS DO NOT INTERFERE WITH FUSE OPERATION.
 4. REMOVE OLD SURGE ARRESTERS.
 5. BOND THE LV NEUTRAL ONTO THE TRANSFORMER TANK.



DRAWN	K.R	01/04/2021
CHECKED	K.R	
QA	QA	
MFG		
APPROVED	KEVIN RISI	
	Tel: +27184685080	
	sales@liveline.co.za	

LIVE LINE TECHNOLOGY www.liveline.co.za		
TITLE MV THREE PHASE H-POLE TRANSFORMER STRUCTURE UGANDA & KENYA.		
SIZE D	DWG NO COMBI - 008/21	REV
SCALE - 1:1	SHEET 1 OF 1	